

<b>Declaration of Performance Nr 13004 dated 2013-12-29</b>	
1. Product name	<b>NOFIRNO®</b>
2. Type identification	NOFIRNO sealing system (filler sleeves and sealant), size range see annex, batch number see packaging
3. Intended use	Sealing system for fire safe wall and floor pipe penetrations
4. Name and contact address of manufacturer	Beele Engineering BV Vierde Broekdijk 12 7122 JD Aalten The Netherlands
5. Name and contact address of authorised representative	Not applicable
6. System of assessment and verification of constancy of performance (AVCP)	System 1
7. Notified Body	Not applicable
8. Technical Assessment Body	<p>Technical Assessment Body No.0620, Kiwa Nederland BV, issued ETA 13/0153 on the basis of ETAG 026 part 2, performed the activities:</p> <ul style="list-style-type: none"> <li>• the evaluation and approval of the products based on initial type assessment (including sampling)</li> <li>• the initial inspection of the production installation and the factory production control</li> <li>• the permanent surveillance and evaluation of the factory production control</li> </ul> <p>and issued certificate of constancy of performance of the product with the unique number 76875</p>

9. Declared performance			
Essential characteristics	Performance	Standard	Harmonised technical specification
Reaction to fire • Classification	Class E	EN-ISO 11925-2 EN 13501-1	ETAG 026 part 2
Resistance to fire • Fire resistance classification	EI 120-C/U and E 120-C/U	EN 1366-3 EN 13501-2	
Air permeability	NPD		
Water permeability	NPD		
Emission of dangerous substances or radiation	NPD		
Mechanical resistance and stability	NPD		
Airborne insulation	NPD		
Water vapour permeability	NPD		
Durability and serviceability Use categories: Type Y <sub>2</sub> , Z <sub>1</sub> , Z <sub>2</sub>  <b>NOFIRNO filler sleeves</b> 1. Durability of physical-mechanical properties  2. Components and materials compatibility  3. Physical-mechanical properties Hardness Density Tensile strength Elongation at break Limited oxygen index (LOI)	No essential change in performance  Compatible with metal pipes, concrete wall and floor and hard plastic conduit pipes  65 – 85 Shore A 1,55 – 1,65 Mg/m <sup>3</sup> ≥ 2,0 MPa ≥ 100 % ≥ 40 %	EOTA TR 024, table 4-2      ISO 7619-1 ISO 2781 ISO 37 ISO 37 ASTM D2863	

9. Declared performance (continued)

Essential characteristics	Performance	Standard	Harmonised technical specification
Durability and serviceability Use categories: Type Y <sub>2</sub> , Z <sub>1</sub> , Z <sub>2</sub>  <b>NOFIRNO sealant</b> 4. Durability of physical-mechanical properties  5. Components and materials compatibility  6. Physical-mechanical properties Density of uncured material Viscosity of uncured material Hardness after curing Elongation at break Limited oxygen index (LOI)	No essential change in performance  Compatible with metal pipes, concrete wall and floor and hard plastic conduit pipes  1,42 – 1,52 Mg/m <sup>3</sup> 30 – 60 g/sec 35 – 55 Shore A ≥ 50 % ≥ 35 %	EOTA TR 024, table 4-2          ISO 2781 Internal test ISO 7619-1 ISO 37 ASTM D2863	ETAG 026 part 2

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Aalten, 2013.12.29



BEELE Engineering BV  
 Beunkdijk 11 NL - 7122 NZ AALTEN  
 Phone: +31 543 461629 Fax: +31 543 461786

J.A. Beele  
 Managing Director